The TCEQ is committed to accessibility.
To request a more accessible version of this report, please contact the TCEQ Help Desk at (512) 239-4357.

Texas Commission on Environmental Quality

CHECKLIST WORKSHEET

MSW USED OIL HANDLER GENERATORS

Regulating Entity Name
.

Date :

Additional I D:

Investigator Name:

Item Number 0 **Description** Proper management of mixtures of UO & hazardous waste.

Answer **Citations** 279.21(a) **Notes**

Item Number 2 **Description** SPCC Plan (SPCC (Spill Prevention, Control and Countermeasures) Plan applies to underground tank systems of more than 42,000 gallons and above ground systems of more than 1,320 gallons, or where the largest above ground tank exceeds 660 gallons.)

Answer **Citations** 279.22 **Notes**

Item Number 3 **Description** USTs in compliance with 40 CFR Part 280 (This applies to underground storage tank (UST) systems with 10% or more of the system volume below ground level (40CFR 280.12).)

.

Answer **Citations** 279.22 **Notes**

Item Number 4 **Description** Approved storage units.

Answer **Citations** 279.22(a) **Notes**

Item Number 5 **Description** Storage units in good condition, not rusted or leaking.

Answer **Citations** 279.22(b) **Notes**

Item Number 6 **Description** Containers & fill pipes have "Used Oil" labels.

Answer **Citations** 279.22(c) **Notes**

Item Number 7 **Description** Proper cleanup & notification of used oil spills.

Answer **Citations** 324.15 **Notes**

Item Number 8 **Description** On-site burning in space heaters.

Answer **Citations** 279.23(c) **Notes**

Item Number 9 **Description** Using registered UO handlers for off-site shipments:

Answer **Citations** 279.24 **Notes**

Item Number 10 **Description** Registered UO handlers TCEQ Registration No:

Answer **Citations** **Notes**

Item Number 11 **Description** Registered UO handlers EPA ID No.:

Answer **Citations** **Notes**